

AREA ACCEPTANCE CERTIFICATE				A-01A		
Asset			Project No.			
Location						
System						
Layout Drawing						
				OK	N/A	S/L
1	Confirm all floor surfaces and gratings are as per design			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm all handrails are complete and correctly installed as per design drawings			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm all ladders, complete with safety hoops and safety bars are correctly installed as per design drawings			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm all doors and windows are installed correctly as per design drawings and specifications			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm all internal wall and floor finishing's are correct to design specification and free from damage			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm all furniture and fittings including sanitary fixtures are installed as per design and free from damage			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm all painting / passive fire protection is correct to design drawings and free from damage			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm special equipment is installed as per design drawings and specifications			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm all wall penetrations are closed and as per design			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Fireproofing material applied according to specification			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Insulating material and thickness in accordance with specification. Vapour barriers installed where required			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm all walkways are correctly identified, have suitable surface friction, and are free from obstructions and tripping hazards			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm area is clean and free of all debris			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
		COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)		
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

LV ELECTRICAL AND INSTRUMENT CABLES			E-01A		
Asset		Project No.			
Location		System			
Tag Number		Termination Drawing			
Layout Drawing		Cable Route Drawing			
			OK	N/A	S/L
1	Cable is the correct type and size as per cable schedule and is a single length i.e. no joints.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Cable glands are the correct type and size and installed correctly. Confirm at least 50mm straight cable before gland, and cable is not under tension.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	On single core cables ensure non-magnetic gland plates and insulated glands are fitted.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check cable supports, cleating and banding are to specification. Confirm any unarmoured cables are in conduit or cable support, and all covers are correctly installed with all bolts tight and in place.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Check bending radius and twist is within manufacturers recommendations along the whole length of cable run.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check cable markers are correct at transits and at each end of the cable.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm cable route and segregation are to design and specifications. Confirm communication cables have at least 300mm segregation from power cables.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm where instrument cable cross over power cables they are at right angles.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm ELV and LV sources are not used in the same cable.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm cable trenching is as per design, correct depth and backfill, and warning markers as per specification, and cable tape installed on the length of the cable as per regulations.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm trenches have a minimum of 75mm bedding material and 300mm width.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Ensure IP sealing washers, earth tags and bonding are fitted to glands, where applicable.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Check earth tag and bonding are correct to design requirements.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Inspect stress relief system and ensure termination is correct to manufacturers specification.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm conductor continuity / phasing is correct.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	With all cores disconnected test insulation resistance values for core to core, core to earth and core to screen. Minimum value: 25 MΩ . 100 MΩ screen to Armour. Record results in table below. (Test volts = 1000V for power cables = 250 / 500V for instrument and control cables)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm terminations and core markings are correct and as per Watercare General Electrical Construction Standard section 12. Confirm cable ends are sealed with heat shrink.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Measure earth loop resistance (power cable only). Confirm < 1Ω.		Ω		<input type="checkbox"/>
19	Confirm spare cores are correctly identified, terminated & earthed.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	Confirm screens are correctly terminated as specified.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

CABLE TEST RECORD

[illegible]

Test Equipment

Make:		Model:		Serial No:		Cal Expiry Date:	
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

HV CABLES				E-02A		
Asset			Project No.			
Location			System			
Tag Number			Termination Drawing			
Layout Drawing			Cable Route Drawing			
				OK	N/A	S/L
1	Cable is the correct type and size as per cable schedule and installed as per the requirements of the Watercare General Electrical Construction Standard. Confirm there are no joints in the cable.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Cable glands are the correct type and size and installed correctly. Confirm at least 50mm straight cable before gland, and cable is not under tension.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	On single core cables ensure non-magnetic gland plates and insulated glands are fitted.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check cable supports, cleating and banding are to specification.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Check bending radius and twist is within manufacturers recommendations along the whole length of cable run.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check cable markers are correct at transits and at each end.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm cable route and segregation are to design and specifications.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm cable trenching is as per design, correct depth and backfill, and warning markers as per specification, and cable markers installed at each change in direction.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Ensure IP sealing washers, earth tags and bonding are fitted to glands, where applicable.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Check earth tag and bonding are correct to design requirements.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Inspect stress relief system and ensure termination is correct to manufacturers specification.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm conductor continuity / phasing is correct.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Complete Insulation Resistance Test (before pressure test): 5kV Megger (Min value 100 MΩ) L1 – L2+L3+E MΩ L2 – L1+L3+E MΩ L3 – L1+L2+E MΩ			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Complete pressure Test: record leakage current. Test Voltage: 15kV DC / Test Duration 15 mins L1 – L2+L3+E mA L2 – L1+L3+E mA L3 – L1+L2+E mA			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm core markings and terminations are correct.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Record torque settings and bolt size: End 'A' Nm mm End 'B' Nm mm			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm mechanical protection is to specification, and all covers are correctly installed with all bolts tight and in place.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Measure earth loop resistance, including gland body to earth path. (max 0.5Ω)			Ω		<input type="checkbox"/>
19	Confirm All prescribed electrical work (PEW) undertaken has been tested in accordance with the Electrical Safety Regulations, attach all relevant documents			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:			
Test Equipment			
Make:	Model:	Serial No:	Cal Expiry Date:
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)
COMPANY			
SIGNATURE			
PRINT NAME			
DATE			

LV and HV SWITCHBOARDS			E-03A		
Asset		Project No.			
Location		System			
Tag Number		Manufacturer			
Layout Drawing		Model			
SLD Drawing		Serial number			
			OK	N/A	S/L
1	Record the following rating information: Volts _____ Amps _____ MVA _____ Secs _____		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm an FAT has been completed and any snag list items have been rectified. Ensure copy of the ESC (electrical safety certificate) from the manufacturer is attached.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Verify nameplate details against datasheet.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Visually inspect all equipment for external damage (including paintwork).		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Visually inspect the switchboard and cubicles for internal damage and cleanliness.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Inspect the switchboard for alignment and secure foundation fixing.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Check all cubicle doors can be fully opened without obstruction.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check earthing is correct and conforms to design specifications.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Measure the earth bar resistance to general earth (max value 0.1Ω).		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm heater and test supply fuse links are correct to drawings.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm the main busbars are fully rated over their whole length for the current and short circuit rating indicated in the single line diagram. Confirm the droppers are rated for the full short circuit rating shown in the single line drawing.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm torque settings of busbar split joint bolts are correct as per manufacturers schedule: bolt size: _____ mm torque: _____ Nm		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm all equipment carries the correct circuit identification.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Check busbar phase identification and phasing is maintained.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	If a main switchboard with an incomer rated at 80A or higher confirm a power meter is installed.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	If a main switchboard confirm that three phase surge protection is installed including a surge diverter which complies with ANSI/IEEE C62.41.2 Cat A, Cat B, Cat C standards. The diverter shall provide auxiliary digital outputs connected to the site PLC/DCS to indicate the status of the unit. The surge diverter unit shall be maintainable by way of replaceable cartridges.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Confirm revenue meeting is installed correctly and ESC (Electrical Safety Certificate) and ROI (record of inspection) is available, attach copy to this record.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19	Ensure all busbars are encapsulated as per design requirements and confirm all 'live' parts are shrouded.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	Check all bolts are correct and that none are missing, and gaskets and seals are not damaged. Ensure all spare cable entries are plugged.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22	'Red Line' mark-up complete.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

23	Ductor test all split joints and record results below.							<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	*Note: vendor to confirm test results.									
Red Phase		Yellow Phase		Blue Phase		Neutral		Earth		
Joint No	Reading	Joint No	Reading	Joint No	Reading	Joint No	Reading	Joint No	Reading	
Comments:										
Test Equipment										
Make:			Model:			Serial No:		Cal Expiry Date:		
	COMPLETED BY: (Construction)			ACCEPTED BY: (Project Engineer)			REVIEWED BY: (Commissioning)			
COMPANY										
SIGNATURE										
PRINT NAME										
DATE										

DISTRIBUTION BOARDS, CONTROL PANELS and JUNCTION BOXES					E-04A		
Asset				Project No.			
Location				System			
Tag Number				Manufacturer			
Layout Drawing				Model			
SLD Drawing				Serial number			
					OK	N/A	S/L
1	Record the following rating information: Volts _____ Amps _____ Phases _____ Number of Circuits _____				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Verify nameplate details against datasheet.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Visually inspect all equipment for internal and external damage (including paintwork) and cleanliness. Inspect the DB for alignment and secure mountings and fixing.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm the installation complies with the Watercare General Electrical Construction Standard, IP rating 65 (or higher) and Ex certification is suitable for location and location is correct to layout drawing.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm circuit identification is as per distribution schedule, terminals correct type and identified.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm MCB's and RCDs installed as per design and rating / curve correct.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Check earthing is correct and conforms to design specifications.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Measure the earth bar resistance to general earth (max value 0.1Ω).				Ω		
9	Confirm all glands are tight and all spare cable entries are plugged and IP washers installed.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Check all doors can be fully opened without obstruction, padlocking facilities are satisfactory and all bolts are correct.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm space heater is correct to drawings (if installed).				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Check gaskets and seals are not damaged and drain and breather plugs are installed.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm main isolator functions correctly.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm phasing is correct.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Record DB insulation resistance test results: 1kV megger (min 10 mΩ)				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	L1–L2, L3, N, E	L2–L1, L3, N, E	L3–L1, L3, N, E	N – E			
	MΩ .	MΩ	MΩ	MΩ			
16	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

ELECTRIC MOTORS					E-05A			
Asset				Project No.				
Location				System				
Tag Number				Manufacturer				
Layout Drawing				Model				
SLD Drawing				Serial number				
Schematic Drawing				Insulation Class				
						OK	N/A	S/L
1	Record the following rating information:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Volts	FLC Amps	Frequency	Power	Phases			
2	Verify nameplate details against datasheet					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm equipment identification is correct and adequate					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Visually inspect equipment for external damage (including paintwork)					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm the feed CB is suitable for the motor size, one CB per motor.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check equipment fixings and mountings are secure, vibration mounts fitted and correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Verify equipment IP rating and certification is suitable for location and spare cable entries are correctly plugged					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check earthing is correct and conforms to design specifications. Confirm an earth terminal has been provided within the main motor terminal enclosure					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	If an anti-condensation heater is installed confirm: <ul style="list-style-type: none"> The heaters are wired to a separate terminal block within the motor terminal box. A miniature circuit breaker or fuse is be connected to the load side circuit of the motor isolator/breaker, allowing the heater to be isolated with the motor. VSD anti-condensation heating (dc injection) shall not be used in place of heaters 					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Test and record motor to earth continuity (max. value 0.5Ω)					Ω		<input type="checkbox"/>
11	Check terminal box gaskets and seals are not damaged, check all bolts are correct and that none are missing					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm Insulation resistance is greater than 1.5MΩ					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Check all connections are correct, secure and cable identifications are correct and fitted e.g. (D.O.L./Star Delta)					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Check that fan is free and cover secure					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Rotate shaft and confirm freedom of movement check uncoupled motor rotates freely					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:								
Test Equipment								
Make:		Model:		Serial No:		Cal Expiry Date:		
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

CHARGERS, BATTERIES and UPS						E-06A		
Asset			Project No.					
Location			System					
Tag Number			Manufacturer / Model					
Layout Drawing			Serial number					
SLD Drawing			Schematic Drawing					
						OK	N/A	S/L
1	Record the following rating information:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Volts	Amps	Frequency	Power	A/Hr			
2	Verify nameplate details against datasheet.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm equipment identification is correct and adequate including associated equipment.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Visually inspect equipment for external damage (including paintwork).					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Check equipment fixings and mountings are secure. Check all bolts are correct and that none are missing, and gaskets and seals are not damaged.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check all doors can be fully opened without obstruction. Confirm clear access and not located below water or chemical lines.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Check earthing is correct and conforms to design specifications					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check all connections are correct, secure and cable identifications are correct and fitted.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm terminal insulation shrouds fitted.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Type, size and rating of protection devices and fuses are correct.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm number and type of batteries in accordance with approved drawings.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Check all battery terminations and links are secure, clean and protected by approved compound.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm all battery links and cables are installed for correct polarity.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm electrolyte levels are correct. Ensure containment of electrolyte under tilt conditions.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Check main battery isolator, and outgoing circuits. Confirm ratings are suitable and to design.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm spare cable entries are correctly plugged.					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Carry out Insulation Resistance test on main AC (disconnect electronics).					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Neutral to earth connection confirmed at one location					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19	Test and record charger to earth continuity (max. value 0.5Ω)					Ω		<input type="checkbox"/>
20	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:								
Test Equipment								
Make:		Model:		Serial No:		Cal Expiry Date:		
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

GENERATOR / ALTERNATOR					E-07A			
Asset				Project No.				
Location				System				
Tag Number				Manufacturer				
Layout Drawing				Model				
SLD Drawing				Serial number				
Schematic Drawing				Insulation Class				
						OK	N/A	S/L
1	Record the following rating information:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Volts	Amps	Frequency	Power	PF			
2	Verify nameplate details against datasheet					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm equipment identification is correct and adequate					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Visually inspect equipment for external damage (including paintwork)					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Check equipment fixings and mountings are secure, vibration mounts fitted and correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check earthing is correct and conforms to design specifications					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Test and record motor to earth continuity (max. value 0.5Ω)					Ω		<input type="checkbox"/>
8	Ensure direction of rotation is clearly marked					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm equipment is suitable for area classification					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Check terminal box gaskets and seals are not damaged					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm installation of non-magnetic gland plate / insulated glands where applicable					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm spare cable entries are correctly plugged, all bolts are correct and that none are missing					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Check all connections are correct, secure and cable identifications are correct and fitted					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm anti-condensation heaters are fitted					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Check air ventilation ducts are clear					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm All prescribed electrical work (PEW) undertaken has been tested in accordance with the Electrical Safety Regulations, attach all relevant documents					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:								
Test Equipment								
Make:		Model:		Serial No:		Cal Expiry Date:		
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

POWER TRANSFORMER						E-08A		
Asset			Project No.					
Location			System					
Tag Number			Manufacturer					
Layout Drawing			Model					
SLD Drawing			Serial number					
Schematic Drawing			Insulation Class					
						OK	N/A	S/L
1	Record the following rating information:							
	Primary Volts	Amps	Frequency	Power	Fault Level	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Secondary Volts	Tap Range	Vector Group					
2	Verify nameplate details against datasheet, equipment identification is correct and adequate					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Visually inspect equipment for external and internal damage (including paint) and cleanliness					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check equipment fixings and mountings are secure and correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm cooling / air ventilation is adequate and intakes / outlets are clear of obstructions					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check earthing is correct and conforms to design specifications					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Test and record earth continuity (max. value 0.5Ω)					Ω		<input type="checkbox"/>
8	Confirm equipment is suitable for area classification					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Check terminal box gaskets and seals are not damaged					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm spare cable entries are correctly plugged, all bolts are correct and that none are missing					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Check connections are correct, secure and cable and terminal identifications are correct and fitted					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm anti-condensation heaters are fitted (if applicable)					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Check HV/MV/LV connections torque settings are to manufacturers recommended torque settings (record results)					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm tap changer operates correctly over design range					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm auxiliary equipment in accordance with approved vendor drawings					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm pressure relief device fitted					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Check oil levels, Sample oil and test where applicable					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Confirm All prescribed electrical work (PEW) undertaken has been tested in accordance with the Electrical Safety Regulations, attach all relevant documents					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:								
Test Equipment								
Make:		Model:		Serial No:		Cal Expiry Date:		
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

ELECTRIC HEATER						E-09A		
Asset				Project No.				
Location				System				
Tag Number				Manufacturer				
Layout Drawing				Model				
SLD Drawing				Serial number				
Schematic Drawing								
						OK	N/A	S/L
1	Record the following rating information:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Volts	Amps	Frequency	Power	Phases			
2	Verify nameplate details against datasheet, equipment identification is correct and adequate					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Visually inspect equipment for external and internal damage (including paint) and cleanliness					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check equipment fixings and mountings are secure and correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm location is correct to layout drawings					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check earthing is correct and conforms to design specifications					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Test and record motor to earth continuity (max. value 0.5Ω)					Ω		<input type="checkbox"/>
8	Confirm equipment is suitable for area classification					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Check terminal box / enclosure gaskets and seals are not damaged					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm spare cable entries are correctly plugged, all bolts are correct and that none are missing					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Check connections are correct, secure and cable and terminal identifications are correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Test continuity of all internal cable cores and heater elements					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Perform heater Insulation Resistance tests and record the results in comment section (min. value 10 MΩ, * Note: disconnect any electronic equipment prior to test)					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm All prescribed electrical work (PEW) undertaken has been tested in accordance with the Electrical Safety Regulations, attach all relevant documents					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:								
Test Equipment								
Make:			Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

Socket Outlet Circuits				E-10A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Model				
SLD Drawing		Schematic Drawing				
			OK	N/A	S/L	
1	Record the following rating information: Volts Amps Phases		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Verify equipment identification is correct and adequate, confirm correct number of outlets and locations		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Visually inspect equipment for external and internal damage and cleanliness		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Check equipment fixings and mountings are secure and correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Confirm location is correct to layout drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Check earthing is correct and conforms to design specifications		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Confirm all outlets are correctly identified with tag number and circuit		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	Confirm equipment is suitable for area classification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Confirm spare cable entries are correctly plugged, all bolts are correct and that none are missing		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Check connections are correct, secure and cable and terminal identifications are correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	Confirm MCB and RCD of circuit is correct, and DB is correctly labelled, and circuits identified		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
12	Confirm distribution board circuit number is in accordance with approved drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
13	Carry out Insulation Resistance test on circuit (min value 10 MΩ @ 500V)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
14	Test and record earth continuity (max. value 0.5Ω)		Ω		<input type="checkbox"/>	
15	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

LIGHTING CIRCUITS				E-11A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Model				
SLD Drawing						
Schematic Drawing						
				OK	N/A	S/L
1	Record the following rating information: Volts Amps Number of light fittings on circuit			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Verify equipment identification is correct and adequate, confirm correct number of lights and locations			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Visually inspect equipment for external and internal damage and cleanliness			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check equipment fixings and mountings are secure and correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm location is correct to layout drawings			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check earthing is correct and conforms to design specifications			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm all light fittings and switches are correctly identified with tag number and circuit			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm equipment is suitable for area classification			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm spare cable entries are correctly plugged, all bolts are correct and that none are missing			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Check connections are correct, secure and cable and terminal identifications are correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm MCB / RCD of circuit is correct and correctly labelled, and circuits identified			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm distribution board circuit number is in accordance with approved drawings			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm all Lamps correct size.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Carry out Insulation Resistance test on circuit (min value 10 MΩ @ 500V)			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Test and record earth continuity (max. value 0.5Ω)			Ω		<input type="checkbox"/>
21	Confirm All prescribed electrical work (PEW) undertaken has been tested in accordance with the Electrical Safety Regulations, attach all relevant documents			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

MISCELLANEOUS EQUIPMENT				E-12A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Model				
SLD Drawing						
Schematic Drawing						
				OK	N/A	S/L
1	Record the following rating information: Volts Amps Power			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Verify equipment identification is correct and adequate.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Visually inspect equipment for external and internal damage and cleanliness			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check equipment fixings and mountings are secure and correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm location is correct to layout drawings			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm equipment is installed as per the manufacture's recommendations and design			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Check earthing is correct and conforms to design specifications			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm all equipment and auxiliaries are correctly identified with tag number and circuit			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm equipment is suitable for area classification including IP rating			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm spare cable entries are correctly plugged, all bolts are correct and that none are missing			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Check connections are correct, secure and cable and terminal identifications are correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm MCB / Fuse rating of circuit is correct and DB is correctly labelled, and circuits identified			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm distribution board circuit number is in accordance with approved drawings			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Carry out Insulation Resistance tests			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Test and record earth continuity (max. value 0.5Ω)			Ω		<input type="checkbox"/>
16	Confirm All prescribed electrical work (PEW) undertaken has been tested in accordance with the Electrical Safety Regulations, attach all relevant documents			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

EARTHING				E-13A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Model				
SLD Drawing		Schematic Drawing				
			OK	N/A	S/L	
1	Confirm earthing assembly is correct and conforms to design specifications		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Verify equipment identification is correct and adequate		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Visually inspect equipment for external and internal damage and cleanliness		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Check earth bar fixings and mountings are secure and correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Confirm location is correct to layout drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Confirm that all bolts / lugs are of correct size and secure		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Perform ductor tests on earth bar assembly with cables disconnected and record the results (max. value 0.1 Ω)		Ω			<input type="checkbox"/>
8	Check connections are greased, secure and cable and terminal identifications are correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	For IS equipment ensure that a separate insulated earth bar is installed in accordance with design specifications		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Confirm all cable sizes are correct to design specifications		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	Confirm equipment is bonded to the main earth		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
12	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

CABLE RACKING / TRAY / CONDUIT / TRANSITS				E-14A		
Asset			Project No.			
Location			System			
Tag Number			Manufacturer			
Layout Drawing			Model			
SLD Drawing			Schematic Drawing			
					OK	N/A
					S/L	
1	Confirm installation is in accordance with design drawings.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm separation maintained between rack systems (HV/MV – LV 600mm).			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm primary & secondary support adequate, Brackets are spaced at minimum 300mm.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm rack / tray material is to correct specification. Heavy duty aluminium.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm all bolts / nuts are fitted and tight and all rough edges and burrs have been removed.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm deflection is limited to 25mm per 6m.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Carry out earth path resistance test on rack / tray and record the results (max. value 0.5Ω)			Ω		<input type="checkbox"/>
8	Confirm rack / tray is not a hazard to personnel, blocking access or preventing removal of equipment			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm rack / tray bonding conforms to design specification			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm insulation spacers are fitted where applicable			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm protective kick plates installed where applicable			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm rack identification is correct to specification			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm transit frames are correctly installed & packed			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm transit identification is correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm rack to transit alignment correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm Conduit saddles spaced at minimum of 1000mm. Confirm appropriate anchors used, wood or fibre plugs are not acceptable.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm Conduit expansion joints provided at minimum 25m intervals and boxing provided at minimum 40m intervals.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

HAZARDOUS AREA CERTIFIED EQUIPMENT			E-15A		
Asset		Project No.			
Location		System			
Tag Number		Manufacturer			
Layout Drawing		Model			
SLD Drawing		Serial Number			
NOTE: These checks are to be completed by a suitably qualified electrical person			OK	N/A	S/L
1	Record the following: Area Hazardous classification: Equipment Ex Classification: Equipment Certifying Authority: Equipment Cert Number:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm the sites Ex register (Verification Dossier) has been updated with the details of this equipment		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm apparatus is appropriate for the area classification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm temperature classification is correct for area		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm apparatus group or sub-group is correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm correct circuit identification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm integrity of enclosure		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm cable entries and stoppers are complete and appropriate & tight		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm electrical connections are tight		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm that earthing and bonding is satisfactory		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm for correct rating of apparatus and components		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm apparatus and wiring systems are not damaged		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm that environmental protection is adequate		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm there are no unauthorised modifications		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm all bolts / screws present and tight & correct type		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm special installation requirements as identified on certificate (suffix 'x') are met		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm that stopper and cable boxes are correctly filled if applicable		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Confirm, if applicable, that conduit runs / fittings are tight and free from corrosion		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ex 'd' Enclosure					
1	Confirm apparatus is clean and corrosion free		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm flame path is free from dirt, paint and corrosion		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm flame path is not damaged		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Clean all blind holes of dirt and grease prior to assembly		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm spigots are correctly fitted and not damaged		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Ensure approved grease has been applied to flange faces, flame path, spigots and bolts, etc.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm flange joint weatherproofing is correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm adjacent steelwork / equipment does not obstruct flame path (Gas group IIA = 10mm, IIB = 30mm, IIC = 40mm)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

9	If sight glasses / indicators are fitted check for damage	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ex 'e' Increased Safety				
1	Confirm enclosure gasket is in good condition and IP rating maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Check terminals are approved and as supplied by manufacturer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Check creepage and clearance distances are maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm terminal links are installed correct to manufacturers design	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm lamp ratings are correct	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm motor gaps / running clearances are satisfactory	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm electrical protection is satisfactory.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check for deterioration of encapsulation materials	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm spare cores terminated & earthed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ex 'n' (zone 2 only)				
1	Carry out checks as per Ex 'e' requirements	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm motor fans and couplings are free to rotate with sufficient clearance	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm minimum IP rating > than IP 54	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ex 's' Special Equipment				
1	Carry out checks as per Ex 'e' requirements	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Check any special requirements as per certificate are adhered to (i.e.: fuses sizes etc.)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ex 'p' Pressurised Enclosure				
1	Confirm enclosure and associated ducting, piping are mechanical sound and free from defects	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Conform pressure / flow indicators, alarm and interlocks function correctly	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ex 'I' Intrinsically Safe				
1	Confirm system installation complies with relevant certification requirements	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm field mounted equipment, cables and JB's are identified as IS circuits	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm fuses and lamps are of correct type / rating as per certification requirement	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm earthing is correct to project specifications	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm cable screens are earthed in accordance with project procedures specifications	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm diode safety barriers are correct type / rating and earthed correctly	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm wiring separation from non-IS circuits is maintained throughout circuit	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:				
Test Equipment				
Make:	Model:	Serial No:	Cal Expiry Date:	
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)	
COMPANY				
SIGNATURE				
PRINT NAME				
DATE				

CONTACTOR STARTER / FUSED SWITCH						E-16A		
Asset				Project No.				
Location				System				
Tag Number				Manufacturer				
Layout Drawing				Model				
SLD Drawing								
Schematic Drawing								
						OK	N/A	S/L
1	Record the following rating information:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Volts	Amps	Phases	Circuit no.	Switchboard			
2	Equipment Clean and free from mechanical damage and installed as per the manufactures recommendations					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Isolator is lockable in the OPEN position					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Isolator is interlocked with the door					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Isolator and Auxiliary switches operate correctly					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Plug in starter withdrawal unit operates correctly					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Plug in starter alignment of main and auxiliary plugs correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Internal wiring secure and clear of door and withdrawal unit					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Door earthed Correctly					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	All control switches, pushbuttons and lamps correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	All Ammeters and scales correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	All Flash Barriers correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:								
Test Equipment								
Make:			Model:		Serial No:		Cal Expiry Date:	
COMPLETED BY: (Construction)			ACCEPTED BY: (Project Engineer)			REVIEWED BY: (Commissioning)		
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

CIRCUIT BREAKER INSTALLATION						E-17A		
Asset				Project No.				
Location				System				
Tag Number				Manufacturer				
Layout Drawing				Model				
SLD Drawing				Serial Number				
Schematic Drawing								
						OK	N/A	S/L
1	Record the following rating information:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Volts	Amps	Phases	Circuit no.	Switchboard			
2	Equipment Clean and free from mechanical damage and installed as per the manufacture's recommendations					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm equipment identification is correct and adequate					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Circuit breaker clean & free from mechanical damage					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	All transit packaging removed					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Busbar connection between fixed / moving parts of CB aligned & complete					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Main plug and socket connector alignment connection correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Secondary plug and socket connector alignment connection correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Busbar shutter operation correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Busbar padlocking operation correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Circuit breaker close and trip mechanism operating manually					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Internal wiring neat and correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:								
Test Equipment								
Make:			Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

BUS DUCTING INSTALLATION				E-18A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Model				
SLD Drawing		Serial Number				
Schematic Drawing						
				OK	N/A	S/L
1	Record the following rating information: Volts Amps Phases Power Switchboard			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Equipment Clean and free from mechanical damage and installed as per the manufactures recommendations			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm support system adequate & complete			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Insulators installed as per manufactures recommendations and free from dust and debris			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm all interconnecting sections fitted			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm penetration integrity suitable for fire rating of bulkhead			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm movement & expansion catered for all terminations			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm terminations at equipment as per manufactures recommendations complete at both ends			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm encapsulation of joints is complete			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm torque settings of busbar split joint bolts are correct as per manufacturers schedule: bolt size: mm torque: Nm			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm bus ducting clear of obstructions			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm earth bonding correct & complete			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm Bus-bar continuity test completed			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Complete ductor test (ohms) and record results			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Complete insulation resistance test (megohms) and record results			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm All prescribed electrical work (PEW) undertaken has be tested in accordance with the Electrical Safety Regulations, attach all relevant documents			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

Cathodic Protection			E-19A		
Asset		Project No.			
Location		System			
Tag Number		P&ID			
Layout Drawing		Schematic Drawing			
			OK	N/A	S/L
Isolating / Insulating Joints					
1	Confirm Insulating joints have a lightning arrestor installed across the insulated joint to protect the joint.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	If a polarisation cell, PCR or equivalent is specified confirm a lightning arrestor has been installed as well.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Where the insulating joints are adjacent to a valve, confirm the arrestor has been connected to the outside pipe flanges, not to the valve body.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cathodic protection power supplies (TR's)					
4	Confirm TRs have been mounted on a concrete plinth that complies with the concrete structure requirements in Watercare's general civil construction standard and the following: <ul style="list-style-type: none"> Extend beyond the side of the TR cabinet by a minimum of 100mm Concrete thickness of minimum 150mm and have 12mm reinforcing at mid-level of the plinth Sloped from the centre of the plinth to 1:100 – if the TR base is an open frame Sloped from the side of the TR cabinet of 1:100 – if the TR base is enclosed and sealed against water ingress Provided with minimum 4x 50NB uPVC penetrations for earth peg and cables 		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Impressed current anode ground beds					
5	Confirm Impressed current anodes have individual cables brought up to a junction box from all anodes		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm Impressed current anodes are located as per the drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sacrificial anode ground beds					
7	Confirm anodes have been supplied and installed packaged in gypsum bentonite backfill in a calico bag		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm the backfill was well wetted prior to backfill		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm individual cables from all anodes have been brought up to a junction box		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm the junction box has been designed to allow easy access to cable terminals. Terminals shall be brass or stainless-steel bolts and/or bus bars, except where mounted in instrumentation control boxes with DIN rail mounts.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm anodes installed in the pipe trench have been installed in the bottom corner of the trench resting on native soil. Where anodes are installed outside the trench it shall be in native soil		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm Anodes have not been laid on scoria, bedding sand or other free draining material.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	The anode bed may be connected temporarily to ensure operation. Following the check, the anode bed must be disconnected until pre-commissioning has been completed or as otherwise specified by Watercare.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Permanent buried reference cells					
14	Confirm the cells have been installed as per the drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm the cells have been supplied and installed in packaged in gypsum bentonite backfill in a calico bag		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

16	Confirm the cells Backfill was thoroughly wetted prior to backfill	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Continuity bonding				
17	Confirm un-welded joints within buried cathodically protected sections of pipeline have been bridged with a continuity bond cable. b) The bond cable shall be: <ul style="list-style-type: none"> As short as practicable to reduce voltage drop Located such that there are no mechanical joints between the connection point and the pipe being bonded 	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Test points				
18	If the test point is surrounded by pavement Confirm a drop tube or soil access box has been provided. b) Drop tubes shall be installed with minimum 300mm native soil in the base. In cases where native soil is too hard to be compacted in the tube or too free draining to enable contact, the fill shall be: <ul style="list-style-type: none"> For corrosion coupons: Washed sand Buried references and other installations: 50% gypsum / 50% bentonite mix c) Fill shall not be scoria, gravel or a similar free draining material.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19	Confirm test points terminating in a test station have two cables connected separately to the structure and terminated separately in the test station, one for potential monitoring the other as a bond cable, regardless of whether bonding is required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	Confirm Interference test points have been installed as close as practicable to the crossing point of two services in an accessible location.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22	Confirm that where the test station is 3m or more from the crossing a permanent zinc reference has been installed mid-way between the protected pipe and the crossing service, ensuring that the cell is no closer than 100mm from either.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Corrosion coupons and electrical resistance probes				
23	Confirm the test station foot has been buried in the pipe trench in the same bedding and surround material as the pipe, facing down towards the pipe invert.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24	Wherever practicable a drop tube shall be provided. Configuration options in order of preference are: i. Single unit with probe foot directly below test station, with a drop tube in the test station connected to the foot ii. Probe foot with drop tube and flush access box buried separately near test station iii. Probe foot buried with permanent zinc reference (supplied with the probe) and no drop tube	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cabling and connections				
25	Confirm that cables have been installed as continuous single length cables without splices or joints.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
26	Confirm cables have been installed in conduit.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
27	Confirm cable continuity has been tested. (Buried cable connections shall be tested prior to recoating connections and backfilling).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Unless shown otherwise in the specific drawings, cable colours shall be:			
	Cable use	Colour		
	Protected pipes in the main CP system	Black		
	Other Watercare pipework (protected or not)	White		
	Customer or foreign pipes or structures	Blue		
	Permanent references	Yellow		
	Sacrificial anodes	Red (may be TPS inner layer)		
	Impressed anodes	Red or Black		

	Continuity cabling for CP	Black			
	Earthing	Green/Yellow			
	The following minimum conductor sizes shall apply:				
	Conductor	Size			
	Potential monitoring (no current)	4mm ²			
	Test point bond cables (impressed systems)	16mm ²			
	Test point bond cables (sacrificial systems)	6mm ²			
	Continuity bond cables (not for earthing)	16mm ²			
	Anode junction box to TR or test station	16mm ²			
	Impressed current anodes (individual)	16mm ²			
	Sacrificial anodes (individual)	6mm ²			
28	Confirm continuity bond cables are as short as practicable to avoid unnecessary voltage drop in the cable. Bond cables for earthing purposes shall comply with relevant regulations.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Equipment labelling and identification specific to cathodic protection					
29	Confirm Labels comply with the general requirements in section 12 of the Watercare General Electrical Construction Standard. Equipment to be labelled are: • Insulating flanges • Test stations • Junction boxes • TRs		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:					
Test Equipment					
Make:		Model:	Serial No:	Cal Expiry Date:	
COMPLETED BY: (Construction)					
COMPANY		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
SIGNATURE					
PRINT NAME					
DATE					

HVAC DUCTWORK INSTALLATION				H-01A		
Asset			Project No.			
Location			System			
Tag Number			Manufacturer			
Layout Drawing			Model			
D&ID Drawing			Serial number			
ISO Drawing			Data Sheet			
					OK	N/A
					S/L	
1	Ductwork complete, satisfactory and in accordance with design drawings and location correct				<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm the installation is as per design, i.e. drain points, valving, instruments, dampers, louvers, screens etc				<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm protective coating satisfactory, Insulation correctly applied and undamaged				<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm flanges secure, sealed and bolts tight, Joints and sealants correct, flexible joints correctly installed and sealed, and duct work internally cleaned				<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm stiffening and turning vanes correctly installed				<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm access door location clearly identified, fastened and sealed				<input type="checkbox"/>	<input type="checkbox"/>
7	Ensure all related equipment checklists are complete				<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm anti-vibration and resilient supports secure and in accordance with manufacturer's instructions				<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm instrument insertions are sealed				<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm supports adequate and correctly installed				<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm pressure/leakage test complete, blanking plates removed, and joints resealed				<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm duct identification labels correctly fitted				<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm test points adequate				<input type="checkbox"/>	<input type="checkbox"/>
14	Earth bonding complete				<input type="checkbox"/>	<input type="checkbox"/>
15	Test and record earth continuity (max. value 0.5Ω)				Ω <input type="checkbox"/>	
16	Air inlets/outlets have bird/insect mesh securely fitted where applicable				<input type="checkbox"/>	<input type="checkbox"/>
17	All grills, louvers, attenuators, filters, diffuser and associated dampers are installed, functional and in the open position.				<input type="checkbox"/>	<input type="checkbox"/>
Comments						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

DAMPER INSTALLATION			H-02A		
Asset		Project No.			
Location		System			
Tag Number		Manufacturer			
Layout Drawing		Model			
D&ID Drawing		Serial number			
ISO Drawing		Data Sheet			
			OK	N/A	S/L
1	Check that the damper is undamaged, clean and installed in accordance with drawings and specifications. Confirm fire rating is as per design (if applicable)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Check that damper blades are sealing, and clearance is satisfactory and that the blades are within the casing when damper is fully open		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Check access is available to damper internals and for maintenance		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm the bulkhead penetration integrity is correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm dissimilar metal isolation is achieved		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm nameplate in readable location, record details		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm airflow direction correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm flanges are sealed and bolted correctly, and gaskets are in accordance with specifications and correctly fitted		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Local external indication is fitted and satisfactory		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Locking quadrant is fitted and satisfactory		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm damper blades move satisfactorily		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm tension spring, or counterbalance weight fitted.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm earthing conforms to design requirements		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm damper controls are as per design, record failure position (OPEN/CLOSED):		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm air supply tubing pressure checks completed		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm fire detection device is operational and commissioned (fusible loop, frangible bulb, fire wire etc)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm auxiliary devices (solenoids, limit switches) have been commissioned and loop tested		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:					
Test Equipment					
Make:		Model:	Serial No:		Cal Expiry Date:
COMPLETED BY: (Construction)					
COMPANY		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
SIGNATURE					
PRINT NAME					
DATE					


AIR HANDLING UNIT INSTALLATION				H-03A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Model				
D&ID Drawing			Serial number				
ISO Drawing			Data Sheet				
					OK	N/A	S/L
1	Confirm the air handling unit and components are undamaged and installed in accordance with approved drawings, specification and manufacture recommendations				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm mounting supports, frames and bolts are correctly installed and tight				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm there is sufficient space for withdrawal purposes and adequate access for maintenance				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm drip tray and drain pipes installed and functional				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm compressor and drive complete				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm anti-condensation heater fitted (where required)				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm all valves are operational and greased				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm piping connections are complete and the unit is internally clean and free of debris				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm where required, refrigeration line complete and supported, sight glass fitted				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm surface coating and insulation is complete and to the correct specification				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm inspection doors and hatches correctly installed and lock operable, gaskets are undamaged. Confirm flanges secure and bolts tight				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm name plate details correct and readable				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm applicable check lists completed for: a) Heating and cooling coils b) Humidifiers c) Auxiliary instruments and remote controls and indications				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm dissimilar metals isolation achieved				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm flow direction correctly indicated				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm earth bonding correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)			
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

BELT DRIVEN FAN INSTALLATION				H-04A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Model				
D&ID Drawing			Serial number				
Termination Drawing			Data Sheet				
					OK	N/A	S/L
1	Confirm the fan unit and components are undamaged and installed in accordance with approved drawings, specification and manufacture recommendations				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm mounting supports, vibration mountings, frames and bolts are correctly installed				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm there is sufficient space for withdrawal purposes and adequate access for maintenance				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm drip tray and drain pipes installed and functional				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Check Impeller secure and clearance satisfactory, confirm the fan turns freely by hand.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm ducting and dampers connections are complete and the unit is internally clean and free of debris. Confirm gaskets are installed in ducting joints and the flexible connection joints (if installed)				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm surface coating and insulation is complete and to the correct specification				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check Impeller secure and clearance satisfactory, Static balance satisfactory, Fan shaft level and bearings aligned, Motor level and aligned, Pulleys aligned, and belts tensioned				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Grease fan and motor bearings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm inspection doors and hatches correctly installed and lock operable, gaskets are undamaged. Confirm flanges secure and bolts tight				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm name plate details and tag plates correct and readable and flow direction correctly indicated				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm guarding is sufficient to prevent access to rotating parts				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm all electrical and instrument check sheets associated with fan are complete				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Record Belt details Manufacturer: Type: Size: Number fitted:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm earth bonding correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

REVERSE CYCLE HEAT PUMP INSTALLATION				H-05A		
Asset			Project No.			
Location			System			
Tag Number			Manufacturer			
Layout Drawing			Model			
D&ID Drawing			Serial number			
Termination Drawing			Data Sheet			
					OK	N/A
					S/L	
1	Confirm the unit and components are undamaged and installed in accordance with approved drawings, specification and manufacture recommendations			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm the size of the unit is suitable for the area to be heated / cooled			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm mounting supports, vibration mountings, frames and bolts are correctly installed			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm the exterior unit is level and if ground mounted is located on a solid surface.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm there is sufficient space for withdrawal purposes and adequate access for maintenance			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm refrigerant and drain pipes are installed and functional			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm refrigerant pipes have been pressure and leak tested			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check Impeller secure and clearance satisfactory, confirm the fan turns freely by hand.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm ducting and dampers connections (if installed) are complete and the unit is internally clean and free of debris.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm filters are installed and clean			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm name plate details and tag plates correct and readable			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm guarding is sufficient to prevent access to rotating parts			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm all electrical and instrument check sheets associated with the system are complete			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Test and record earth continuity (max. value 0.5Ω)			Ω		<input type="checkbox"/>
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

INSTRUMENT INSTALLATION				I-01A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Model				
P&ID Drawing			Serial number				
Loop Drawing			Data Sheet				
					OK	N/A	S/L
1	Instrument checked, and all data correct against data sheet				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Instrument condition satisfactory, complete and free from any mechanical damage				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Instrument installed correctly to all relevant layout, termination, loop and hook-up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Instrument accessible for maintenance and clear of any obstructions				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Instrument correctly mounted, secure, orientation correct, elevated correct and free from vibration. Any local indicators are clearly visible				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Process connections correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Pneumatic connections correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Hydraulic connections correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Electrical connections correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Test and record earth continuity (max. value 0.1Ω)				Ω		<input type="checkbox"/>
11	Spare electrical entries and process connections suitably plugged / capped				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	EOL resistor fitted (if applicable). Record resistor value:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Instrument Tag No. fixed. Label visible. Label and Tag meet project standards				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Calibration certificate confirmed valid and attached to this check sheet				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

CONTROL VALVE INSTALLATION			I-02A		
Asset		Project No.			
Location		System			
Tag Number		Manufacturer			
Layout Drawing		Model			
P&ID Drawing		Serial number			
Loop Drawing		Data Sheet			
			OK	N/A	S/L
Valve					
1	Valve checked, and all data correct against data sheet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Valve condition satisfactory, complete and free from any mechanical damage		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Body and Trim material correct to data sheet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Leakage class correct to data sheet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Valve sizing correct to data sheet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Instrument installed correctly to all relevant layout, termination, loop and hook-up drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm valve has been installed in the correct direction of flow		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Actuator					
1	Failure action as per data sheet (Open, Close or Last)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Working pressure correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Fluid type correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Hydraulic connections correct (if any)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Pneumatic connections correct (if any), air regulator as per data sheet.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Electrical connections correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Hand wheel operation correct (if any)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check earthing is correct and conforms to design specifications		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Test and record earth continuity (max. value 0.1Ω)		Ω		<input type="checkbox"/>
Comments:					
Test Equipment					
Make:	Model:	Serial No:	Cal Expiry Date:		
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)		
COMPANY					
SIGNATURE					
PRINT NAME					
DATE					

ORIFICE PLATE INSPECTION				I-03A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Model				
P&ID Drawing			Serial number				
			Data Sheet				
					OK	N/A	S/L
1	Confirm device conforms to the data sheet				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm upstream orifice markings: a) the word 'upstream' b) the Tag No. c) the ANSI flange class, followed by RF d) the nominal size of DN (mm) e) the measured orifice diameter 'd' (mm)				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm concentricity DN a-a is within 0.1 mm for DN < 200 mm or within 0.2 mm for DN >= 200 mm (FE only)				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm difference between any two measurements of plate thickness is within 0.001 x DN (in mm) (FE only)				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm plate flatness along any diameter is within 0.001 x pipe ID				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm that the surface finish of the throat and plate are free from visible scratches and indentations				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm throat edges are sharp and free from burrs				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Check there is no light reflected from the corners of square edged plates				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm that the location and size of the bleed hole (where applicable) conforms to standard drawings / data sheet				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Measure and record diameter of orifice at upstream face on the vertical (a) and horizontal (b) axes and (c) for overall diameter (a) _____ (b) _____ (c) _____				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
							
11	Confirm orifice plate is not damaged and shows no signs of corrosion				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	

	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)
COMPANY			
SIGNATURE			
PRINT NAME			
DATE			

INSTRUMENT TUBING INSTALLATION					I-04A			
Asset				Project No.				
Location				System				
Tag Number								
Layout Drawing								
P&ID Drawing								
Loop Drawing				Hook-Up Drawing				
						OK	N/A	S/L
1	Instrument tubing installed and supported correctly				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Tubing materials correct, and tubing has no sign of damage or welding spots				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Confirm all tubing is blown clear and dry prior to test. All dirt and cutting debris removed from tubing				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	All instrument tube fittings and isolation valves are correctly installed as per relevant drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	All instruments that cannot be subjected to the pressure test should be removed from the pressure test				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Record Pressure Test Parameters (Use soapy water test to check that the joints are leak free).				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	Service	Test Specification	Test Pressure	Test Medium	Soak Duration			
	Impulse Line - (Non-Hydraulic)	1.5 x Design PressurekPa	min (≥ 10)			
	Hydraulic Line - (Impulse and Signal)	1.5 x Design PressurekPa	min (≥ 15)			
	Signal Line - (Vacuum or Atmospheric)	Fixed Pressure	150 kPa	min (≥ 10)			
	Signal Line - (Non-Hydraulic Lines)	Max Operating PressurekPa	min (≥ 10)			
8	Hydraulic lines flushed to NAS specification 1638 Class 7				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Hydraulic lines depressurised and capped after test				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Tubing cleaned and drained, and blown dry				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	Tubing is correctly re-connected				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Comments: Impulse Lines are defined as lines connected to process and Signal Lines are defined as lines connected to non-process								
Test Equipment								
Make:		Model:		Serial No:		Cal Expiry Date:		
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)			
COMPANY								
SIGNATURE								
PRINT NAME								
DATE								

INSTRUMENT CALIBRATION							I-05A		
Asset					Project No.				
Location					System				
Tag Number					Manufacturer				
Layout Drawing					Model				
P&ID Drawing					Serial Number				
Loop Drawing					Hook-Up Drawing				
							OK	N/A	S/L
1	Confirm all Instrument data correct as per project data sheet					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Instrument Checked for Damage					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Instrument Tag Number Attached to Instrument					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Confirm all Electrical and process connections correct					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Input Range:		Output Range:			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Confirm calibration is current and calibration sticker attached to Instrument					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Attach vendor calibration certificate, or complete calibration and record results below					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Calibration (using certified test equipment)									
Analogue Instruments									
Range	0%	25%	50%	75%	100%	75%	50%	25%	0%
Input (Engineering value)									
Output (mA/ Digital)									
Digital Instruments									
Switch / Relay	Set Point			Rising / Falling			Switch Contact		
							NO / NC		
							NO / NC		
							NO / NC		
							NO / NC		
Comments:									
Test Equipment									
Make:	Model:			Serial No:			Cal Expiry Date:		
	COMPLETED BY: (Construction)			ACCEPTED BY: (Project Engineer)			REVIEWED BY: (Commissioning)		
COMPANY									
SIGNATURE									
PRINT NAME									
DATE									

INSTRUMENT / UCP PANEL INSTALLATION				I-06A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Model				
Schematic Drawing		Serial number				
GA drawing		Data Sheet				
			OK	N/A	S/L	
1	Confirm nameplate details and internal/external tagging is as per datasheet and drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Confirm all external and internal equipment is undamaged (including paintwork/lamps switches)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Confirm panel external /internal fittings and mountings are secure and to design		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Confirm panel alignment is correct and location correct to equipment layout drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Confirm anti-condensate heater is correct type and rating (if fitted)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Confirm that all doors/removable sides are free from obstruction and are accessible		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Confirm gaskets and seals are not damaged, confirm IP rating is suitable for location		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	Confirm all bolts are correct and that none are missing		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Confirm that panel instrument and electrical earthing is correct to project earthing specifications		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Test and record earth continuity (max. value 0.1Ω)		Ω		<input type="checkbox"/>	
11	Confirm internal panel equipment PSU's, MCB's, Fuses, Barriers etc are correct type and rating		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
12	Confirm all internal panel equipment is installed and secure as per panel internal G.A. Drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
13	Confirm all internal connections are correct, secure and cable identifications are correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
14	Confirm all Intrinsically Safe and AC/DC wiring /terminal segregation is correct and clearly identified.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
15	Confirm that any pneumatic/ hydraulic connections are correct (include "Purge" apparatus).		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
16	Confirm electro-mechanical relays/breakers secure and free from damage		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
17	Confirm solid state electronics secure and free from damage		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

MISC. PROCESS ANALYSERS INSTALLATION				I-07A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Model				
Termination Drawing			Serial number				
P&ID Drawing			Data Sheet				
					OK	N/A	S/L
1	Analyser checked, and all data correct against project /vendor data sheet				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Analyser condition satisfactory, complete and free from any mechanical damage				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Analyser cabling and electrical connections are complete and installed correctly				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Analyser EX and IP ratings are correct / maintained for installed area classification				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Sampling system filters, strainers, coalesces and contaminant traps installed correctly				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	External sample dryers installed as per Hook up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Sample probe installed correctly with respect to process termination point				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Loop inlets / outlets connected at correct process termination point				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Sample conditioning carrier gas system installed correctly as per Hook up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Sample line electric heat tracing installed correctly				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Sample line pump(s) installed correctly as per Hook up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Instrument air supply installed correctly as per Hook up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Potable water supply installed correctly as per Hook up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	System drains, and vents discharge termination point correct as per Hook up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Actuated sample stream switching valves installed as per Hook up drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Analyser enclosure cooling / circulation / HVAC fans installed and wired correctly				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Analyser enclosure anti-condensation heater system installed and wired correctly				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19	Analyser oven / enclosure heaters system operable installed and wired correctly				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	Confirm the electrical earthing is correct to project earthing specifications				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21	Test and record earth continuity (max. value 0.5Ω)				Ω		<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)			
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

FIRE SUPPRESSION SYSTEM INSTALLATION				I-08A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Model				
P&ID Drawing		Serial number				
Loop Drawing		Data Sheet				
			OK	N/A	S/L	
1	Equipment checked, and all data correct against data sheet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Ensure the equipment has been installed in line with the FPANZ Code of Practice for Gaseous Fire Suppression Systems – COP 01		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Equipment condition satisfactory, complete and free from any mechanical damage		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Equipment installed correctly to all relevant layout, termination, loop and hook-up drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Equipment correctly mounted, secure, orientation correct, elevated correct and free from vibration, accessible for maintenance and clear of any obstructions. Any local indicators are clearly visible		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Equipment Tag Labels visible. Label and Tag meet project standards		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Confirm the number and capacity of equipment CO2 / N2 / Air bottles is correct as per design		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	Confirm all nozzles are clear and un-obstructed, confirm spray path and coverage is as per design		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Confirm all pipework and tubing has been pressure tested and is free of debris		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Confirm all pipework is suitably installed with adequate supports and protection		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	Confirm all pressure vessels have been commissioned and are within certification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
12	Confirm all actuating devices, solenoids etc have been commissioned		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
13	Confirm any Frangible or heat activated bulbs are of the correct rating		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
14	Confirm equipment Earthing / Bonding is correct to project specification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
15	Test and record earth continuity (max. value 0.5Ω)		Ω			<input type="checkbox"/>
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						


VALVE and PENSTOCK INSTALLATION				M-01A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Type and Model				
P&ID Drawing		Serial number				
ISO Drawing		Data Sheet				
				OK	N/A	S/L
1	Equipment checked, and all data correct against data sheet. Vendor test documentation complete.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Specification correct for the service and conditions			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Condition satisfactory, complete, and free from any mechanical or paint damage			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Equipment installed correctly to all relevant layout, Isometric, and P&ID's, flow direction is correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Installed equipment supported at the right reaction/support points			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Equipment is readily accessible for operation and maintenance and is clear of any obstructions			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	All handwheels, lever functions etc function correctly. Any local indicators are clearly visible and correctly set up.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm valve stem / gearbox indication match's the actual position of the valve and that the stem and ball/flap/butterfly etc are correctly attached and aligned.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Valve and Penstock stops are set (where applicable), and the equipment operates smoothly across its full range			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm penstock guides and slides are as per deign, square, and seals and grouting are adequate			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Spindles are greased with a suitable grease for type and environment			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm gearbox is correctly greased, repack if required by the vendor manual			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm any actuators are installed as per design and correct for the application			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm electrical and instrument checks have been completed on any actuators			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

STRAINERS FILTERS AND SCREENS INSTALLATION				M-02A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Type and Model				
P&ID Drawing			Serial number				
ISO Drawing			Data Sheet				
					OK	N/A	S/L
1	Equipment checked, and all data correct against data sheet. Vendor test documentation complete.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Equipment specification correct for the service including filter medium /strainer mesh size				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Equipment condition satisfactory, complete and free from any mechanical damage				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm paint finish is satisfactory, is free from damage and correct to the project specification				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Equipment installed correctly to all relevant layout, Isometric, and P&ID's, flow direction is correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Equipment is readily accessible for operation and maintenance and is clear of any obstructions				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	All handwheels, lever functions etc function correctly. Any local indicators are clearly visible and correctly set up.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm screen guides and slides are as per design, square, and seals and grouting are adequate				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Check access for operations and maintenance is adequate				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm spindles are greased with a suitable grease for type and environment				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm any gearboxes are correctly greased, repack if required by the vendor manual				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Check DP instruments if fitted are complete / available				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm any actuators are installed as per design and correct for the application and electrical and instrument checks have been completed				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Check cleanliness of chamber and element				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm all drains and vents completed				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							


MISCELLANEOUS MECHNICAL INSTALLATION				M-03A		
Asset			Project No.			
Location			System			
Tag Number			Manufacturer			
Layout Drawing			Type and Model			
P&ID Drawing			Serial number			
ISO Drawing			Data Sheet			
					OK	N/A
					S/L	
1	Equipment checked, and all data correct against data sheet. Vendor test documentation complete.				<input type="checkbox"/>	<input type="checkbox"/>
2	Specification correct for the service and conditions				<input type="checkbox"/>	<input type="checkbox"/>
3	Condition satisfactory, complete and free from any mechanical damage				<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm paint finish is satisfactory, is free from damage and correct to the project specification				<input type="checkbox"/>	<input type="checkbox"/>
5	Equipment installed correctly to all relevant layout, Isometric, and P&ID's, flow direction is correct. Equipment supported at the right support/reaction points.				<input type="checkbox"/>	<input type="checkbox"/>
6	Equipment is readily accessible for operation and maintenance and is clear of any obstructions				<input type="checkbox"/>	<input type="checkbox"/>
7	All handwheels, lever functions etc function correctly. Any local indicators are clearly visible and correctly set up.				<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm sliding feet are not obstructed, and the bolts are correctly installed with washers fitted				<input type="checkbox"/>	<input type="checkbox"/>
9	Check access for operations and maintenance is adequate				<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm all pipework is correctly aligned and gaskets are of the correct type				<input type="checkbox"/>	<input type="checkbox"/>
11	Ensure all flanges are correctly bolted and torqued				<input type="checkbox"/>	<input type="checkbox"/>
12	Check that all access ladders and platforms are secure				<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm Spindles, bearings, moving parts etc are greased with a suitable grease for type and environment				<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm all vents and drains are installed correctly				<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

PUMP INSTALLATION				M-04A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Type and Model				
P&ID Drawing		Serial number				
ISO Drawing		Data Sheet				
				OK	N/A	S/L
1	Equipment checked, and all data correct against data sheet. Vendor test documentation complete.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Specification correct for the service and conditions			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Condition satisfactory, complete and free from any mechanical damage			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm paint finish is satisfactory, is free from damage and correct to the project specification			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Equipment installed correctly to all relevant layout, Isometric, and P&ID's, flow direction is correct			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm mechanical seal and auxiliaries are as per design and suitable for the application			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm correct relief arrangement installed			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Equipment is readily accessible for operation and maintenance and is clear of any obstructions			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm cold alignment has been completed and check sheet completed			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Record coupling gap DBSE:			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm earthing is to project specification			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Install coupling and guard, ensure guard is adequate			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm mounting is as per the manufacturers recommendation including torque values			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm all pipework is correctly aligned and gaskets are of the correct type and bolts torqued			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm all vents and drains are installed correctly			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm oilers are installed (as required) and filled with the correct grade oil			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm pump skid and drip tray are clear of debris			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

SUBMERSIBLE PUMP INSTALLATION				M-05A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Type and Model				
P&ID Drawing			Serial number				
ISO Drawing			Data Sheet				
					OK	N/A	S/L
1	Equipment checked, and all data correct against data sheet. Vendor test documentation complete. Name plate data correct including tag plate.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Specification correct for the service and conditions				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Condition satisfactory, complete and free from any mechanical and paint damage				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Equipment installed correctly to all relevant layout, Isometric, and P&ID's, flow direction is correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Equipment is readily accessible for operation and maintenance and is clear of any obstructions				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm air release vent is installed and operational				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm earthing is to project specification				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm all pipework is correctly aligned and gaskets are of the correct type and bolts torqued				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electrical submersible type							
9	Confirm number of riser spools are as per drawing				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm riser spool flange faces are undamaged and square				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm riser spool flange gaskets and stud bolts correct to design specification				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm number of spider restraints are as per design				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Line Shaft type							
13	Number of riser spools are as per drawing				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Riser spool flange faces are undamaged and square				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Number of line shafts are as per drawing				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

COLD ALIGNMENT DATA SHEET					M-06A			
Asset				Project No.				
Location				System				
Tag Number				Manufacturer				
Layout Drawing				Type and Model				
P&ID Drawing				Serial number				
ISO Drawing				Data Sheet				
					OK	N/A	S/L	
1	Confirm manufacturers figures for coupling alignment, record specified cold offsets below				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Check equipment skid is level to tolerance and signed as per approved design				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Carry out a pre-welding alignment and record				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Equipment skids have been welded prior to the fitting of pipe				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Carry out soft foot check and record				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Check all pipework is complete and flange alignment is correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Loosen off all pipework to the driven equipment				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	Split coupling, remove spacer (if fitted), bolts and guard				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Record DBSE				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Install Coupling and guard. Tension bolts as per spec.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	Using the following gauge positions, complete the tables below				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
								
	Suction and Discharge pipes loose				Suction pipe loose, Discharge pipe tight			
	A1	A2	R1	R2	A1	A2	R1	R2
0								
90								
180								
270								
	Suction pipe tight, Discharge pipe loose				Suction and Discharge pipes tight			
	A1	A2	R1	R2	A1	A2	R1	R2
0								
90								
180								
270								
Comments:								

Test Equipment			
Make:	Model:	Serial No:	Cal Expiry Date:
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)
COMPANY			
SIGNATURE			
PRINT NAME			
DATE			

BELT ALIGNMENT DATA SHEET				M-07A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Type and Model				
P&ID Drawing		Serial number				
ISO Drawing		Data Sheet				
				OK	N/A	S/L
1	Confirm manufacturers figures for coupling alignment, record specified cold offsets below			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Check equipment skid is level to tolerance and signed as per approved design			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Using the following gauge positions, complete the tables below			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
 <p>Deflection 16mm per metre of span</p> <p>Force</p> <p>Δ</p> <p>D</p> <p>d</p> <p>L</p> <p>$1/2$</p> <p>X1 X2</p>						
4	Record Belt details:		Manufacturer: _____	Belt No.: _____		
	Type: _____		Size: _____	Number fitted: _____		
	Pulley Centres 'L': _____		Drive Pulley diameter 'd': _____	Driven Pulley diameter 'D': _____		
	Required Deflection Δ : _____		Actual Deflection Δ : _____	Pulley Misalignment X1 & X2: ____		
5	Install Coupling and guard. Tension bolts as per spec.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Machine mounting bolts tight			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:						
Test Equipment						
Make:		Model:		Serial No:		Cal Expiry Date:
	COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

DIESEL ENGINE INSTALLATION				M-08A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Type and Model				
P&ID Drawing			Serial number				
ISO Drawing			Data Sheet				
					OK	N/A	S/L
1	Confirm engine correct to design specification and vendor Test Documentation Available				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm engine installation is correct as per design drawings and name plate details correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm skid location and level is correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Engine barring facilities operational				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Rig saver system (if fitted) operational				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Visually inspect engine for external damage including paintwork				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm exhaust system is completed to design specification including supports, and bellows and insulation				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm air intake is completed to design specification including supports, filters installed and internally clean				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm all associated pipe work including flexible pipe are complete, damage free and aligned				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Alignment completed as required and recorded				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Ensure all guards fitted and provide adequate protection				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Ensure all auxiliary systems complete				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm Anti-vibration mounts correct and secure				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm installation of integral cooling fan is correct as per design drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm diesel fuel emergency shut off valve operational				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm diesel fuel system is complete and operational including line filters				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm earth boss and strap are fitted				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Confirm engine skid is clear of debris and contaminates				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

AIR COMPRESSOR INSTALLATION				M-09A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Type and Model				
P&ID Drawing			Serial number				
ISO Drawing			Data Sheet				
					OK	N/A	S/L
1	Confirm compressor is correct to design specification and vendor test documentation is available				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm compressor installation is correct as per design drawings and name plate details correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm skid location and level is correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Visually inspect compressor for external damage including paintwork				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm all associated pipe work including flexible pipe are complete, damage free and aligned				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm reclaimers are as per design specification				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm dryers are installed as per design drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm electrical check sheets have been completed				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm instrument check sheets have been completed				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	If the compressor is diesel driven complete the diesel engine check sheet				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Ensure all guards fitted and provide adequate protection				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Ensure all auxiliary systems complete				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm Anti-vibration mounts correct and secure				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm installation of integral cooling fan is correct as per design drawings				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm earth boss and strap are fitted				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm engine skid is clear of debris and contaminants				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

LIFTING EQUIPMENT INSTALLATION				M-10A			
Asset			Project No.				
Location			System				
Tag Number			Manufacturer				
Layout Drawing			Type and Model				
P&ID Drawing			Serial number				
ISO Drawing			Data Sheet				
					OK	N/A	S/L
1	Confirm equipment is correct to design specification and vendor test documentation is available				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm installation is correct as per design drawings and name plate details correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm skid location and level is correct				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm access for maintenance is as per the Watercare Standard, permanent access is provided to gantry cranes etc.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm travel and operation of equipment is unrestricted				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm equipment identification and SWL clearly marked				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm all associated lifting gear/tackle is correctly installed and certified i.e. sheave blocks, beam clamps, S.W.L. marking, shackles, slings, eyebolts, etc.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm utility connections are complete				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm alignment checks complete on all associated equipment's				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm stops are fitted to ends of runway beams				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm lifting appliances are certified i.e.: Beam trolleys, Combined trolley hoists, Chain hoists etc				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Personnel protection and safety devices are operational				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm Load test certificates, Design Verification Certificate and Registration number are attached to this ITR.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:							
Test Equipment							
Make:		Model:		Serial No:		Cal Expiry Date:	
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							

RELIEF / SAFETY VALVE INSTALLATION				M-11A		
Asset			Project No.			
Location			System			
Tag Number			Manufacturer			
Layout Drawing			Type and Model			
P&ID Drawing			Serial number			
ISO Drawing			Data Sheet			
					OK	N/A
					S/L	
1	Confirm equipment is correct to design specification and vendor test documentation is available				<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm installation is correct as per design drawings and name plate details correct				<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm name plate details correct				<input type="checkbox"/>	<input type="checkbox"/>
4	Attach test / calibration sheets				<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm equipment installation is correct as per design drawings and has no damage				<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm seal wire integrity correct				<input type="checkbox"/>	<input type="checkbox"/>
7	Record Valve details:				<input type="checkbox"/>	<input type="checkbox"/>
	Balanced / Conventional:		Body material:			
	Bellows material:		Nozzle Material:			
	Orifice size:		Rating:			
	Cold set Pressure: Bar g		Back Pressure: Bar g			
	Data Sheet Setting: Bar g		Operating Temperature: oC			
8	Record Spring details:				<input type="checkbox"/>	<input type="checkbox"/>
	Length:		Coil diameter:			
	No of Coils:		Material:			
	Wire Diameter:		Colour Code Number:			
9	Record Calibration details.				<input type="checkbox"/>	<input type="checkbox"/>
	Test Medium:		Cold set Pressure: Bar g			
	Lifting Pressure: Bar g		Re Seat Pressure: Bar g			
10	Record Leak Test details.				<input type="checkbox"/>	<input type="checkbox"/>
	Leak Test Pressure (90%): Bar g					
	Duration: mins		Leak Rate: (bubble per minute)			
Comments:						
COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)		
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

[illegible]

SPRINKLER / DELUGE / CO2 SUPPRESSION				M-13A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Type and Model				
P&ID Drawing		Serial number				
ISO Drawing		Data Sheet				
			OK	N/A	S/L	
1	Equipment checked, and all data correct against data sheet. Vendor test documentation complete.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Specification correct for the service and conditions and design is as per NZS 4541		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Condition satisfactory, complete and free from any mechanical damage		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Confirm paint finish is satisfactory, is free from damage and correct to the project specification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Equipment installed correctly to all relevant layout, Isometric, and P&ID's		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Equipment is readily accessible for operation and maintenance and is clear of any obstructions		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Horizontal pipe runs installed with required 'fall' and drain holes installed where required as per design.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	Correct number and type of nozzles, heads and or frangible bulbs		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Trigger system complete and correctly installed. All E&I checksheets completed		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Fusible loop pressure tested (if applicable)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	Pipework and cylinders hydrostatically tested and in date.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
12	Certificate of compliance issued as per NZS 4541		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

VENDOR SUPPLIED PACKAGED SKIDS				M-14A		
Asset		Project No.				
Location		System				
Tag Number		Manufacturer				
Layout Drawing		Type and Model				
P&ID Drawing		Serial number				
ISO Drawing		Data Sheet				
			OK	N/A	S/L	
1	Equipment checked, and all data correct against data sheet. Name plate details correct.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Specification correct for the service and conditions and design		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Condition satisfactory, complete and free from any mechanical damage		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Confirm paint finish is satisfactory, is free from damage and correct to the project specification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Equipment installed correctly to all relevant layout, Isometric, and P&ID's		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	All piping and manways complete and adequately supported, correct gaskets installed.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	All drains (including skid drains) installed and clear		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	All insulation as per vendor drawings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Shipped loose items clearly identified and checked		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	FAT Completed to an approved procedure. Copy of outstanding punch list items attached		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	All on skid equipment correctly aligned and appropriate guards installed. Equipment free to rotate.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
12	Dissimilar metal insulation kits used where applicable		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
13	All valves operate through full range and are in the correct direction of flow		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
14	All instrumentation installed as per vendor documentation and project standards		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
15	All electrical equipment / cabling installed as per Vendor documentation and project standards		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
16	All interface and termination points correct and complete		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
17	Earth bonding correct and complete		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
18	Skid package internally and externally clean		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
19	All vendor documentation and drawings available and as-built		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

CENTRIFUGE			M-19A		
Asset		Project No.			
Location		System			
Tag Number		Manufacturer			
Layout Drawing		Type and Model			
P&ID Drawing		Serial number			
ISO Drawing		Data Sheet			
			OK	N/A	S/L
1	Confirm equipment is correct to design specification and vendor test documentation is available		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm installation is correct as per design drawings and name plate details correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm materials of construction are suitable for application including internal coatings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm name plate details correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Attach pressure and material test certificates to this check sheet		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Attach proof of qualification for engineering tradespeople		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Visually inspect tank for internal and external damage including internal and external coatings		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm bolts and seals are tight on all assemblies		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Check all associated pipework is aligned correctly		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm decanter bowl relief / venting arrangements correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm vibration dampers are mounted correctly		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm all associated internal equipment is correct to design specification (vibration & temperature sensors)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Confirm all associated external fittings are correct to specification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Confirm lifting lugs are installed correct and to design specification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Confirm bowl shaft is free to move by hand and direction arrow in place		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16	Confirm flushing and cleaning in place		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17	Confirm lubrication points are accessible and in place (bearings, gearbox)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18	Where applicable confirm sliding feet are not obstructed, and bolts are correctly installed with washers fitted		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19	Confirm machine guards are available and properly installed		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20	Confirm no other machinery is in the same area as decanter in such a way that vibrations or dynamic forces can be transmitted to the decanter.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:					
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)		
COMPANY					
SIGNATURE					
PRINT NAME					
DATE					

SYSTEM PIPING COMPLETION CERTIFICATE						P-01A			
Asset			Project No.						
Location			System						
Layout Drawings			Line Numbers						
P&ID Drawings									
ISO Drawings									
							OK	N/A	S/L
1	Confirm the pipework is as per the isometrics and P&ID ‘s. Ensure any discrepancies have been correctly approved and as built.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm piping material and valve specification is as per design and all tags are correct.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm QA pack and NDT PWHT are complete.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check for correct direction and orientation for inline filters strainers and directional flow valves.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Orifice and flow meter flanges have required upstream and downstream run clearance.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check all thermowells and air release valves are installed as per P&ID’s.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm all pipe supports installed as per spec and design including pipe anchors, sliders, PTFE pads etc.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm mechanical checks are complete on all equipment in the system i.e. valves, strainers.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm fall on pipe work is correct and as per design.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm Pre-Pressure Test checks complete (P-02A) as required.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm Piping Pressure Test complete (P-03A) as required.						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Confirm Flange management complete (P-04A).						<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Comments:									
		COMPLETED BY: <small>(Construction)</small>		ACCEPTED BY: <small>(Project Engineer)</small>		REVIEWED BY: <small>(Commissioning)</small>			
COMPANY									
SIGNATURE									
PRINT NAME									
DATE									

PRE-PRESSURE TEST PIPELINE CHECK				P-02A		
Asset		Project No.				
Location		System				
Layout Drawings		Line Numbers				
P&ID Drawings						
ISO Drawings						
			OK	N/A	S/L	
1	Confirm the pipework is as per the isometrics and P&ID 's. Ensure any discrepancies have been correctly approved and as-built.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	Confirm piping material and valve specification is as per design and all tags are correct		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Confirm QA pack and NDT PWHT complete		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Check for correct direction and orientation for inline filters strainers and directional flow valves		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Orifice and flow meter flanges have required upstream and downstream run clearance		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Check all thermowells are installed as per P&ID's		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
7	Confirm all pipe supports installed as per spec and design including pipe anchors, sliders, PTFE pads etc.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	Confirm mechanical checks are complete on all equipment within the test limits i.e. valves, strainers		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Confirm fall on pipe work is correct and as per design		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Confirm flange management is complete as per check list (P-04)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
11	Confirm that hydro vents and drains have been correctly installed for venting and draining of the system		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
12	Check sealant on screwed connections is as specification		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
13	Confirm line is adequately supported for hydrotesting		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
14	All ball valves half open for testing		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
15	Have check valves internals been removed and bagged and tagged by P&ID		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
16	Confirm all items which are not rated for the test pressure have been removed such as instrumentation, flow meters etc.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
17	Confirm any test equipment required e.g. pressure recorders, have valid calibration certificates		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
18	Confirm barriers and signage have been setup to restrict access to required persons		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
19	Confirm site talk held to explain risks to all persons on the site		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Comments:						
Test Equipment						
Make:	Model:	Serial No:	Cal Expiry Date:			
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

PIPING PRESSURE TEST CERTIFICATE				P-03A		
Asset		Project No.				
Location		System				
Layout Drawings		Line Numbers				
P&ID Drawings						
ISO Drawings						
			OK	N/A	S/L	
1	Confirm NDT PWHT complete and QA release note issued		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
2	List below all spool numbers and relevant Isometrics (where applicable), or attach copy of relevant sheet of subcontractors Hydro-test pack		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
3	Confirm Pre-Pressure Test Check Sheet P-02 is complete		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
4	Attach approved test plan / procedure with test limit P&ID clearly marked		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
5	Release for pressure test		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
6	Pressure Test. Record the following:					
	Test date:		Ambient Temp:			
	Design Pressure:		Test Pressure:			
	Recorder serial No:		Test Gauge Serial No:			
	Test Medium:		Duration of Test:			
	Pressure at start of test:		Pressure at end of test:		PASS/FAIL:	
7	Attach Recorder chart or printout		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
8	Depressurise and drain the system, disconnect all test equipment		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
9	Confirm system is flushed, dried and disinfected as required		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
10	Confirm all items removed prior to the test (i.e. instruments, check valves etc.) have been re-instated		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
List all spool numbers and relevant Isometrics (where applicable)						
Line Number		Isometric drawing numbers				
Comments:						
	COMPLETED BY: (Construction)	ACCEPTED BY: (Project Engineer)	REVIEWED BY: (Commissioning)			
COMPANY						
SIGNATURE						
PRINT NAME						
DATE						

FLANGE MANAGEMENT CERTIFICATE				P-04A			
Asset			Project No.				
Location			System				
Layout Drawings			Line Numbers				
P&ID Drawings							
ISO Drawings							
					OK	N/A	S/L
1	Confirm all flange types are correct for the service and to the design and project specifications. Size, Pattern and Class.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Confirm all flanges faces have been cleaned, are undamaged and are correctly aligned.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Confirm all gaskets are undamaged, correct for the service, flange type, design, and project specification.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirm gaskets have been correctly installed.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Confirm all bolts correct for the service and to the design and project specifications including material and size.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Confirm all bolts and washers are present, correctly certified and are not counterfeit.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Confirm all bolts have been lubricated, tightened using the correct bolt tightening pattern and to the correct torque for the flange and gasket type.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Confirm all joints in this system have been tagged to identify that they have been flanged managed and details entered in the table below.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Confirm Isolation sleeves and washers used where required.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Confirm insulation joints used where required (confirm on P&ID), and insulation test completed >1MΩ				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Confirm Joints have been correctly loaded and supported. No load transferred onto joints during assembly, handling, and installation.				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
List all flanged joints and relevant Isometrics							
Joint Number / Identifier		Isometric drawing numbers		Joint Number / Identifier		Isometric drawing numbers	
Comments:							
		COMPLETED BY: (Construction)		ACCEPTED BY: (Project Engineer)		REVIEWED BY: (Commissioning)	
COMPANY							
SIGNATURE							
PRINT NAME							
DATE							